



**LABORATORY FOR TESTING OF MACHINERY,
EQUIPMENT AND DEVICES**
CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD

2, Industrialna Str., Stara Zagora, Bulgaria,
Tel.: +359 42 620 368 Fax: +359 42 602 377 ctec@ctec-sz.com

TEST REPORT
IEC 60204-1
Safety of machinery - Electrical equipment of machines
Part 1: General requirements

Report Reference No 2e-20-248
Compiled by (+ signature) Srebranov
Witnessed by (name + signature) Chavalinov
Approved by (name + signature) Hristov



[Handwritten signature]

Date of issue 28.02.2020

Testing Laboratory LABORATORY FOR TESTING OF MACHINERY, EQUIPMENT
AND DEVICES TO CENTER FOR TESTING AND EUROPEAN
CERTIFICATION

Address 2, Industrialna Str., Stara Zagora, Bulgaria,
Tel.: +359 42 620 368 Fax: +359 42 602 377

Testing location/procedure TL [X] SMT [] TMP [] WMP []

Address As above

Applicant's name "Studio Grif" Ltd.

Address Bulgaria, Plovdiv, 136 Maritsa Str., ZIP 4000
Tel.: +359 887 629 283, e-mail: contact@flatdog.eu

Test specification:

Standard IEC 60204-1 (Fifth Edition) + A1:2008

Non-standard test method N/A

Test item description Machine for direct printing on cotton Flatdog white Smart

Trade Mark "FlatDog"

Manufacturer "Studio Grif" Ltd.

Model/Type reference FlatDog Smart Evolution

Ratings 220V; 50-60Hz; 3 A

Machine No 00006

Copy of marking plate:

Test item particulars	
Classification of installation and use	Stationary appliance
Supply Connection	The electrical equipment of a machine is connected to one incoming supply.
.....	
.....	
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement	Pass
- test object does not meet the requirement	Fail
Testing	
Date of receipt of test item	
Date (s) of performance of tests	12.02.2020
General remarks:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a comma (point) is used as the decimal separator.	
General product information:	



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
4	GENERAL REQUIREMENTS		P
4.4	Physical environment and operating conditions		P
4.4.1	Electrical equipment suitable for the physical environment and operating conditions of its intended use.		P
4.4.2	Electromagnetic compatibility (EMC): Equipment shall not generate electromagnetic disturbances above levels that are appropriate for its intended operating environment and shall have a level of immunity to electromagnetic disturbances so that it can function in its intended environment (IEC 61000-6-1 or IEC 61000-6-2 and CISPR 61000-6-3 or IEC 61000-6-4 give general EMC emission and immunity limits.) Are there sufficient measures to limit the generation of electromagnetic disturbances, i.e. conducted and radiated provided? (E.g. power supply filtering; cable shielding; enclosures designed to minimize RF radiation; RF suppression techniques; design of functional bonding system, using conductors with low RF impedance and as short as practicable.	See test reports: № 2emc-20-248/28.02.2020 № 2emc-e-20-248/28.02.2020	P
4.4.3	Electrical equipment shall be capable of operating correctly in the intended ambient air temperature. (Minimum requirement: air temperatures of +5 °C and +40 °C)		P
4.4.4	Electrical equipment shall be capable of operating correctly when the relative humidity is up to 50 % at a maximum temperature of +40 °C		P
4.4.5	Electrical equipment shall be capable of operating correctly at altitudes up to 1 000 m above mean sea level.		P
4.4.6	Electrical equipment shall be adequately protected against the ingress of solids and liquids (see 11.3)		P
4.4.7	Electrical equipment shall withstand ionizing and non-ionizing radiation.		N/A
4.4.8	Electrical equipment shall withstand vibration, shock and bump.		P
4.5	Electrical equipment designed to withstand the effects of transportation and storage within a temperature range of - 25 to + 55 °C.		P
4.6	Heavy or bulky electrical equipment of the machine provided with suitable means for handling.		N/A
4.7	Electrical equipment is installed and operated in accordance with the supplier's instruction.		P

5	INCOMING SUPPLY CONDUCTOR TERMINATIONS AND DEVICES FOR DISCONNECTING AND SWITCHING OFF		
5.1	Incoming supply conductor terminal		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
5.1	Electrical equipment of a machine connected to one single power supply (For large complex machinery comprising a number of widely-spaced machines working together in a coordinated manner, there can be a need for more than one incoming supply depending upon the site supply arrangements)		P
	Power supply conductors terminated to main disconnecting device of electrical equipment (unless a plug is provided for disconnection)		P
	Neutral conductor clearly indicated in technical documentation with "N" (see cl. 16.1)		P
	No connection between neutral conductor and protective bonding circuit nor combined PEN-terminals. Exception: a connection may be made between the neutral terminal and the PE terminal at the point of the connection of the power supply to the machine for TN-C systems.	No connection between N and PE	P
	All terminals of incoming supply clearly marked in acc. with cl. 16.1 (symbols acc. to EN 60445)		P
5.2	Terminal for connection to external protective earthing system		P
	For each incoming supply, a terminal shall be provided in the vicinity of the associated phase conductor terminals for connection of the machine to the external protective earthing system or to the external protective conductor, depending upon the supply distribution system.		P
	Cross section of incoming PE conductor acc. to cl. 5.2, table 1. (Where an external protective conductor of a material other than copper is used, the terminal size shall be selected accordingly. See also 8.2.2).		P
	Protective earth identified either by graphic symbol, letters "PE", or bicolour combination GREEN / YELLOW	combination GREEN / YELLOW	P
5.3	Supply disconnecting device		P
5.3.1	A supply disconnecting device shall be provided: – for each incoming source of supply to a machine – for each on-board power supply.		P
5.3.2	Type of power supply disconnecting device:		—
	a) Switch-disconnector, acc. to EN 60947-3 for appliance category AC-23 B or DC-23 B		P
	b) Disconnector with or without fuses, with aux. contact (acc. to EN 60947-3)		N/A
	c) Power circuit breaker suitable for isolation (acc. to EN 60947-2)		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	d) any other switching device in accordance with an IEC product standard for that device and which meets the isolation requirements of IEC 60947-1 as well as a utilization category		N/A
	e) Plug/socket combination for electrical load (requirements see cl. 5.3.3)		P
5.3.3	Disconnection device has to fulfil all of the following requirements		—
	- isolate the electrical equipment from the supply and have only one OFF (isolated) and only one ON position marked with "O" and "I"		P
	- visible contact gap or a position indicator which cannot indicate OFF (isolated) until all contacts are actually open and the requirements for the isolating function have been satisfied		P
	- have an external operating means e.g. a handle (except power operated CB's)		P
	- coloured black or grey recommended (If used as an emergency stop, red/yellow combination selected)	red/yellow	P
	- be provided with a means permitting it to be locked in the OFF position (padlocks). When so locked, remote as well as local closing shall be prevented		P
	- disconnect all live conductors of its power supply circuit (For TN supply systems, the neutral conductor may or may not be disconnected except in countries where disconnection of the neutral conductor (when used) is compulsory.)		P
	Requirements for plug/socket combination as a disconnection device: - Breaking capacity of the plug/socket combination: sufficient to interrupt the current of the largest motor when stalled together with the sum of the normal running currents of all other motors and/or loads. - further see. cl. 13.4.5 a) to f)		P
5.3.4	The operating means are easily accessible and located between 0,6 m and 1,9 m above the servicing level.	0,6 m	P
5.3.5	Only the following circuits need not be disconnected by the supply disconnecting device: - lighting circuits for lighting needed during maintenance or repair; - plug and socket outlets for the exclusive connection of repair or maintenance tools and equipment; - under voltage protection circuits that are only provided for automatic tripping in the event of supply failure; - circuits supplying equipment that should normally remain energized for correct operation - control circuits for interlocking Such circuits are provided with their own disconnecting device.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Circuits not disconnected by the supply disconnecting device have: - permanent warning labels in accordance with cl. 16.1		N/A
	- a statement is included in the maintenance manual		N/A
	- additionally one or more of the following is applied; - a permanent warning label in accordance with 16.1 is affixed in proximity to each excepted circuit, or - the circuit is separated from other circuits, or - the conductors are identified by colour taking into account the recommendation of Cl.13.2.4.		N/A
5.4	Disconnecting devices to prevent of unexpected start-up:		—
	- Devices for the prevention of unexpected start-up are provided These devices are appropriate and convenient for the intended use, are suitably placed, and readily identifiable as to their function and purpose (for example by a durable marking in accordance with cl. 16.1).		P
	- Means are provided to prevent inadvertent and/or mistaken closure of these devices either at the controller or from other locations		P
	- Devices that do not fulfil the isolation function (e.g. a contactor switched off by a control circuit) are only used for situations that include: - inspections; - adjustments; - no hazardous work on the electrical equipment (for example replacement of plug-in devices without disturbing existing wiring)		N/A
5.5	Devices for disconnecting electrical equipment		—
	- Requirements to devices for disconnecting electrical equipment to enable work to be carried out when it is de-energised and isolated: - appropriate and convenient for the intended use; - suitably placed; - readily identifiable as to which part or circuit of the equipment is served (for example by durable marking in accordance with 16.1 where necessary). - Additional means are provided to prevent of inadvertent and/or mistaken closure of these devices either at the controller or from other locations		P
	- Where it is necessary to work on individual parts of the electrical equipment of a machine, or on one of a number of machines fed by a common conductor bar, conductor wire or inductive power supply system, a disconnecting device is provided for each part, or for each machine, requiring separate isolation.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
5.6	Protection against unauthorized, inadvertent and/or mistaken connection		—
	For devices acc. to cl. 5.4(disconnecting electrical equipment) and 5.5 (prevention of unexpected start-up) locking means in OFF position are provided and no remote reconnection is possible.		P
	Where a non-lockable disconnecting device is provided (for example withdrawable fuse-links, withdrawable links), other means of protection against unintended energising are used.		N/A
	Where plug/socket combinations according to 5.3.2 e) are used for the purpose of prevention of unexpected start-up the are so positioned that they can be kept under the immediate supervision of the person carrying out the work.		P

6	PROTECTION AGAINST ELECTRIC SHOCK		P
6.2.2	Protection against direct contact		—
	Live parts that are located inside enclosures have to be conform to the relevant requirements of Clauses 4, 11, and 14 and have to have a protection against direct contact of at least IP2X or IPXXB.	see test report 2ae-20-248/28.02.2020 cl. 2	P
	Where the top surfaces of the enclosure are readily accessible, the minimum degree of protection against direct contact provided by the top surfaces shall be IP4X or IPXXD.	see test report 2ae-20-248/28.02.2020 cl. 2	P
6.2.2 a	Opening an enclosure (i.e. opening doors, lids, covers, and the like) is possible only when: a) Either the use of a key or tool is necessary for access and: - all live parts, that are likely to be touched when resetting or adjusting devices intended for such operations while the equipment is still connected are protected against direct contact to at least IP2X or IPXXB - live parts on the inside of doors are protected against direct contact to at least IP1X or IPXXA.	use of a key	P P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
6.2.2 b	<u>b)</u> Or the opening of an enclosure (i.e. opening doors, lids, covers, and the like) is possible only if disconnection is provided for all live parts inside the enclosure before it can be opened. Exception: If a special device or tool (intended for use only by skilled or instructed persons) as prescribed by the supplier is provided that can be used to defeat the interlock and that intends that: - it is possible at all times while the interlock is defeated to open the disconnecting device and lock the disconnecting device in the OFF position or otherwise prevent unauthorised closure of the disconnecting device; - upon closing the door, the interlock is automatically restored - all live parts, that are likely to be touched when resetting or adjusting devices intended for such operations while the equipment is still connected are protected against direct contact to at least IP2X or IPXXB - live parts on the inside of doors shall be protected against direct contact to at least IP1X or IPXXA - relevant information is provided with the electrical equipment like instructions on the procedures for securing the machine for safe maintenance and information on the residual risks. - means are provided to restrict access to live parts behind doors not directly interlocked with the disconnecting means to skilled or instructed persons. - parts still alive after switching off are protected at least IP 2X or IP XXB and marked with a warning sign in accordance with 16.2.1  Excepted from this marking are: - parts that can be live only because of connection to interlocking circuits and that are distinguished by colour as potentially live in accordance with 13.2.4 - the supply terminals of the supply disconnecting device when the latter is mounted alone in a separate enclosure.		N/A
6.2.2 c	c) Or the opening without the use of a key or a tool and without disconnection of live parts shall be possible only when all live parts are protected against direct contact to at least IP2X or IPXXB. Where barriers provide this protection, either they shall require a tool for their removal or all live parts protected by them shall be automatically disconnected when the barrier is removed.		N/A
6.2.3	Protection by insulation of live parts:		



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Live parts are completely covered with insulation that can only be removed by destruction and that is capable of withstanding the mechanical, chemical, electrical, and thermal stresses to which it can be subjected under normal operating conditions.		P
	Paint, varnish lacquer etc. not used as the unique insulation layer.		P
6.2.4	Protection against residual voltages		—
	Live parts with residual voltage greater than 60 V after a time period of 5 s after disconnection of the supply shall be discharged until this interferes with the proper functioning of the equipment. Except are components with charges of $\leq 60 \mu\text{C}$ ($\rightarrow$ equivalent to capacitor with less than $1\mu\text{F}$ or 60V).		N/A
	Where pins of plugs or similar devices after withdrawal are exposed, discharge time is $\leq 1\text{s}$. Otherwise such conductors are protected against direct contact to at least IP2X or IPXXB.	see test report 2ae-20-248/28.02.2020 cl. 6	P
	If above requirements cannot be achieved, additional disconnecting devices or appropriate warning devices shall be applied (e.g. warning acc. cl. 16.1).		N/A
6.2.5	For protection by barriers, 412.2 of IEC 60364-4-41 is applied.		N/A
6.2.6	For protection by placing out of reach, 412.4 of IEC 60364-4-41 shall apply. For protection by obstacles, 412.3 of IEC 60364-4-41 is applied.		N/A
6.3	Protection against indirect contact		P
6.3.2	Prevention of the occurrence of a touch voltage		—
6.3.2.2	Protection by provision of: - class II electrical devices or apparatus (double insulation, reinforced insulation or by equivalent insulation in accordance with IEC 61140) or - switchgear and control gear assemblies having total insulation in accordance with IEC 60439-1 or - supplementary or reinforced insulation in accordance with 413.2 of IEC 60364-4-41.		N/A
6.3.2.3	Protection by electrical separation. For this type of protection, the requirements of 413.5 of IEC 60364-4-41 apply.		P
6.3.3	Protection by automatic disconnection of supply.		
6.3.3 a)	Use of overcurrent protective device for automatic cut-off in the event of an insulation failure in a TN-System. Where disconnection within the time specified in Clause A.1 cannot be assured, supplementary bonding is provided as necessary to meet the requirements of Clause A.3.		N/A



[illegible]

7.	PROTECTION OF EQUIPMENT		P
7.2.	Overcurrent protection Unless otherwise specified by the user, the supplier of the electrical equipment is not responsible for providing the overcurrent protective device for the supply conductors to the electrical equipment (see Annex B).		P
7.2.2.	On the installation diagram data necessary for selecting the overcurrent protective device are stated for each incoming feeder. (see 7.2.10 and 17.4)		P
7.2.3	Power circuits:		



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Devices for detection and interruption of overcurrent, selected in accordance with 7.2.10, are applied to each live conductor. And, none of the following conductors, as applicable, is disconnected without disconnecting all associated live conductors: – the neutral conductor of a.c. power circuits; – the earthed conductor of d.c. power circuits; – d.c. power conductors bonded to exposed conductive parts of mobile machines.		P P N/A N/A
	Cross section area of neutral conductor is at least equal to the phase conductor. No overcurrent protective/ disconnecting device is required.		P
7.2.4	Control circuits		—
	Conductors of control circuits directly connected to the supply voltage and of circuits supplying control circuit transformers are protected against overcurrent in accordance with 7.2.3.		P
	Conductors of control circuits supplied by a control circuit transformer or d.c. supply: see 9.4.3.1		—
7.2.5	Socket outlets and their associated conductors		—
	Overcurrent protection is provided for the circuits feeding the general purpose socket.		P
7.2.6	Lighting circuits		—
	Lighting circuits are protected separate from other circuits.		N/A
7.2.7	Transformers		—
	Transformers are protected in accordance with the manufacturer's instructions and includes: - avoiding tripping due to transformer magnetizing inrush currents - avoiding a winding temperature rise in excess of the permitted value for the insulation class when there is a short circuit at the secondary terminals. - type and setting of the overcurrent protective device in accordance with the recommendations of the transformer supplier.		P
7.2.8	Location of overcurrent protective devices:		—
	- located at the point where a reduction in the cross sectional area of the conductors or another change reduces the current-carrying capacity of the conductors.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	<u>Exceptions:</u> - current carrying capacity of the conductors is at least equal to that of the load and - conductors between the point of reduction of current-carrying capacity and the position of the overcurrent protective device is ≤ 3 m and - the conductor is protected e.g. by an enclosure or duct.		N/A
7.2.9	Selection of overcurrent protective devices		—
	The rated short-circuit breaking capacity I_{cn} is at least equal to the prospective fault current at the point of installation. Additional currents other than from the supply (e.g. from motors, from power factor correction capacitors) shall be taken into consideration.		P
	Reduced breaking capacity is permitted, where another protective device is installed at supply side with the necessary breaking capacity. (In that case, the characteristics of the two devices shall be co-ordinated so that the let-through energy (I^2t) of the two devices in series does not exceed that which can be withstood without damage to the overcurrent protective device on the load side and to the conductors protected by that device. See Annex A of IEC 60947-2).		N/A
	Where fuses are provided as overcurrent protective devices, a type readily available in the country of use shall be selected, or arrangements shall be made for the supply of spare parts.		N/A
7.2.10	Rating and setting of overcurrent protective devices:		—
	Rated current of fuses or overcurrent setting of other protective devices selected as low as possible, but adequate for anticipated overcurrents.		P
	The rated current of overcurrent protective device is determined by the current carrying capacity of the conductors to be protected in accordance with Cl. 12.4, D.2 and the maximum allowable interrupting time t in accordance with Clause D.3, taking into account the needs of coordination with other electrical devices in the protected circuit.		P
7.3	Protection of motors against overheating		N/A
7.3.1	Overload protection for all motors provided for ratings of > 0.5 kW in continuous operation.		N/A
	Protective device may be omitted for motors, which cannot be overloaded.		N/A
	<u>Exceptions:</u> In applications where an automatic interruption of the motor operation is unacceptable (for example fire pumps), the means of detection shall give a warning signal to which the operator can respond.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
7.3.2	Protection achieved by overload protection device: - detection in each live conductor - switching off of all live conductors (not necessary to switch of neutral conductor)		P
	For special duty motors, appropriate protective devices are recommended		N/A
7.3.3	Protection achieved by over-temperature protection device: Is recommended in situations where the cooling can be impaired (for example dusty environments)		N/A
7.3.4	Protection achieved by current limiting protection: Where protection against the effects of overheating in three phase motors is achieved by current limitation, the number of current limitation devices may be reduced from 3 to 2.		N/A
7.4	Abnormal temperature protection: Resistance heating or other circuits that are capable of attaining or causing abnormal temperatures and can cause a hazardous situation are provided with suitable detection to initiate an appropriate control response.		N/A
7.5	Protection against supply interruption or voltage reduction and subsequent restoration: Where a supply interruption or a voltage reduction can cause a hazardous situation, damage to the machine, or to the work in progress, undervoltage protection is provided.		N/A
	Upon restoration of supply voltage, automatic or unexpected restarting of machine prevented.		N/A
	Undervoltage protection does initiate appropriate control responses to ensure necessary coordination of groups of machines working together		N/A
7.6	Motor overspeed protection: Overspeed protection is provided where overspeeding can occur and could possibly cause a hazardous situation.		N/A
7.8	Phase sequence protection: Where an incorrect phase sequence of the supply voltage can cause a hazardous situation or damage to the machine, protection shall be provided.		N/A
7.9	Protection against overvoltage due to lightning and to switching surges: - Devices are connected to the incoming terminals of the supply disconnecting device.		P

8	EQUIPOTENTIAL BONDING		P
8.2	Protective bonding circuit		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
8.2.1	Where the conductance of structural parts of the electrical equipment or of the machine is less than that of the smallest protective conductor connected to the exposed conductive parts, a supplementary bonding conductor is provided.		N/A
	In IT distribution systems, the machine structure is part of the protective bonding circuit and insulation monitoring is provided.		N/A
	Exposed conductive parts of equipment in accordance with 6.3.2.3 (Protection by electrical separation) are not connected to the protective bonding circuit.		P
8.2.2	Protective conductors		—
	Protective conductors shall be identified in accordance with 13.2.2.		P
	Copper conductors are preferred.		P
	Where other material is used, its electrical resistance per unit length shall not exceed that of the allowable copper conductor and such conductors shall be not less than 16 mm ² in cross-sectional area.		N/A
	The cross-sectional area of protective conductors shall be determined in accordance with the requirements of: —543 of IEC 60364-5-54; or —7.4.3.1.7 of IEC 60439-1, as appropriate. This requirement is met in most cases if it is in accordance with Table 1 of this standard (see 5.2).		P
8.2.3	Continuity of the protective bonding circuit		
	All exposed conductive parts are connected to the protective bonding circuit in accordance with 8.2.1. Parts that are mounted so that they do not constitute a hazard because cannot be touched on large surfaces or grasped with the hand and they are small in size (less than approximately 50 mm × 50 mm) or they are located so that either contact with live parts, or an insulation failure is unlikely need not be connected to the protective bonding circuit		P
	Where a part is removed the protective bonding circuit for the remaining parts isn't interrupted.		P
	Current-carrying capacity of connection and bonding points cannot be impaired by mechanical, chemical, or electrochemical influences (e.g. electrolytic corrosion on aluminium parts)		P
	Metal ducts of flexible or rigid construction and metallic cable sheaths are not used as protective conductors. Nevertheless they are connected to the protective bonding circuit.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Where the electrical equipment is mounted on lids, doors, or cover plates, continuity of the protective bonding circuit shall be ensured. The use of a protective conductor (see 8.2.2) is recommended.		P
	For cables that are exposed to damage (for example flexible trailing cables) the continuity of the protective conductors are ensured by appropriate measures (for example monitoring).		N/A
8.2.4	No means of interruption of the protective bonding conductor are provided.		P
	As well the protective bonding circuit does not incorporate a switching device or an over current protective device (for example switch, fuse).		P
	Removable current collectors, plug/socket combinations or withdrawable plug-in units: The protective bonding circuit is interrupted by a first make last break contact. (see also 13.4.5)		N/A
8.2.6	Protective conductor connecting points: have no other function and are not intended to attach or connect appliances or parts.		P
	Each protective conductor connecting point is marked or labelled as such using the symbol IEC 60417-5019  or the letters PE or by use of bicolour GREEN / YELLOW	bicolour GREEN / YELLOW	P
8.2.7	Mobile machines with on-board power supplies: The protective bonding system is connected to a single protective bonding terminal. This protective bonding terminal is the connection point for a possible additional external incoming power supply.		N/A
8.2.8	Electrical equipment having earth leakage currents higher than 10 mA a.c. or d.c.: Additional protective bonding requirements: - Cross section of protective conductor $\geq 10 \text{ mm}^2$ CU or 16 mm^2 AL - OR Second protective conductor of at least the same cross sectional area if above cross section is impracticable - OR monitoring of continuity of protective conductor with automatic disconnection function.	see test report 2ae-20-248/28.02.2020 cl. 1	P N/A N/A N/A
	Additionally a warning label is provided adjacent to the PE terminal.		N/A

9	CONTROL CIRCUITS AND CONTROL FUNCTIONS
9.1.	Control circuit



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
9.1.1	Control circuit supply: Control transformers mandatory only when more than one motor starter or two control devices are used.		P
	Control transformers with separate windings are used for supplying the control circuits.		P
	Where several transformers are used, the secondary voltages are in phase.		N/A
	Separate windings on transformer for DC supplies connected to PE.		P
9.1.2	The nominal voltage of control supply does not exceed 277 V when supplied from a transformer.		P
9.1.3	Control circuits are provided with overcurrent protection in accordance with 7.2.4 and 7.2.10.		P
9.2.	Control functions		P
	Safety related control functions in accordance with ISO 13849-1 (2006), ISO 13849-2 (2003) and /or IEC 62061 (see 9.4.1)		—
9.2.1	Start functions operating by energizing the relevant circuit (see 9.2.5.2).		P
9.2.3	Operating modes		—
	Suitable means are prevented for unauthorized or inadvertent mode selection if hazardous situations can result.		P
	Mode selection by itself does not initiate machine operation. A separate actuation of the start control has to be stated by the operator.		P
	Indication of the selected operating mode is provided (e.g. the position of a mode selector, the provision of an indicating light, a visual display indication).		P
9.2.4	Where it is necessary to suspend safety functions and/or protective measures (for example for setting or maintenance purposes), protection is ensured.		P
9.2.5	Operation		—
	Prevention of movement of the machine in an unintended or unexpected manner is taken after any stopping of the machine. (e.g. due to locked-off condition, power supply fault, battery replacement, lost signal condition with cableless control)		P
	When a machine has more than one control station, measures are provided to ensure that initiation of commands from different control stations do not lead to a hazardous situation.		N/A
9.2.5.2	Start of an operation is possible only when all of the relevant safety functions and/or protective measures are in place and are operational.		P
	Where safety functions and/or protective measures cannot be applied for certain operations, manual control of such operations are by hold-to-run controls, together with enabling devices, as appropriate.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	In the case of machines requiring the use of more than one control station to initiate a start, each of these control stations shall have a separate manually actuated start control device. The conditions to initiate a start are: - all required conditions for machine operation are met - and all start control devices are in the released (off) position - then all start control devices have to be actuated concurrently (see 3.6).		N/A
9.2.5.3	Stop category 0 and/or stop category 1 and/or stop category 2 stop functions are provided as indicated by the risk assessment and the functional requirements of the machine (see 4.1).	category 0	P
	Stop functions override related start functions		P
	Facilities to connect protective devices and interlocks are provided, where required. If such a protective device or interlock causes a stop of the machine, it may be necessary for that condition to be signalled to the logic of the control system. The reset of the stop function does not initiate any hazardous situation.		N/A
	Where more than one control station is provided, stop commands from any control station is effective when required by the risk assessment of the machine.		N/A
9.2.5.4	Emergency operations (emergency stop, emergency switching off)		—
	Emergency stop or emergency switching off commands are sustained until it is reset.		P
	This reset is possible only by a manual action at that location where the command has been initiated.		P
	The reset of the command does not restart the machinery but only permit restarting.		P
	It is not be possible to restart the machinery until all emergency stop commands are reset.		P
	It is not be possible to reenergize the machinery until all emergency switching off commands are reset.		N/A
9.2.5.4.2	The emergency stop does function either as a stop category 0 or as a stop category 1.	category 0	P
	- it overrides all other functions and operations in all modes;		P
9.2.5.4.3	Emergency switching off is provided where: -Protection against direct contact is achieved only by placing out of reach or by obstacles (see 6.2.6) - or there is the possibility of other hazards or damage caused by electricity.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Emergency switching off is accomplished by electromechanical switching devices, effecting a stop category 0 of machine actuators connected to this incoming supply.		N/A
9.2.5.5	Movement or action that can result in a hazardous situation are monitored by providing, for example, overtravel limiters, motor overspeed detection, mechanical overload detection or anti-collision devices.		N/A
9.2.6	Other control functions		—
9.2.6.2	No type 1 two-hand control device is used for the initiation of hazardous operation. It need type 2 or type 3 two-hand control devices for such operations.		N/A
9.2.6.3	Enabling control: Enabling control are arranged in the way to minimize the possibility of defeating, e. g. by requiring the de-activation of the enabling control device before machine operation may be reinitiated. It is not possible to defeat the enabling function by simple means.		N/A
9.2.6.4	Combined start and stop controls: Push-buttons etc. that alternately initiate and stop motion are provided only for functions, which cannot result in a hazardous situation.		N/A
9.2.7	Cableless control station		N/A
9.2.7.1	Means shall be provided to readily remove or disconnect the power supply of the operator control station (see also 9.2.7.3).		N/A
	Means (for example key operated switch, access code) are provided, as necessary, to prevent unauthorized use of the operator control station.		N/A
	Each operator control station carries an unambiguous indication of which machine(s) is (are) intended to be controlled by that operator control station.		N/A
9.2.7.2	Measures shall be taken to ensure that control commands: – affect only the intended machine; – affect only the intended functions.		N/A
	Measures are taken to prevent the machine from responding to signals other than those from the intended operator control station(s).		N/A
	Where necessary, means are provided so that the machine can only be controlled from operator control stations in one or more predetermined zones or locations.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
9.2.7.3	Operator control stations include a separate and clearly identifiable means to initiate the stop function of the machine or of all the operations that can cause a hazardous situation. The actuating means to initiate this stop function are not marked or labelled as an emergency stop device, even though the stop function initiated on the machine can fulfil an emergency stop function.		N/A
	Stopping of the machine and preventing a potentially hazardous operation is automatically initiated in the following situations: – when a stop signal is received; – when a fault is detected in the cableless control system; – when a valid signal (which includes a signal that communication is established and maintained) has not been detected within a specified period of time (see Annex B), except when a machine is executing a pre-programmed task taking it outside the range of the cableless control where no hazardous situation can occur.		N/A
9.2.7.4	Machines having more than one operator control station, including one or more cableless control stations, have measures provided to ensure that only one of the control stations can be enabled at a given time.		N/A
	An indication of which operator control station is in control of the machine is provided at suitable locations as determined by the risk assessment of the machine. Exception: a stop command from any one of the control stations are effective when required by the risk assessment of the machine.		N/A
9.2.7.5	Battery-powered cableless operator control stations: A variation in the battery voltage does not cause a hazardous situation.		N/A
	A clear warning is given to the operator when a variation in battery voltage exceeds specified limits.		N/A
	Under those circumstances, the cableless operator control station remains functional long enough for the operator to put the machine into a non- hazardous situation.		N/A
9.3	Protective interlocks		P
9.3.1	The reclosing or resetting of an interlocking safeguard does not initiate hazardous machine operation.		P
9.3.2	Where overtraveling an operating limit (for example speed, pressure, position) can lead to a hazardous situation, means are provided to detect when a predetermined limit(s) is exceeded and initiate an appropriate control action.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
9.3.3	The correct operation of auxiliary functions is checked by appropriate devices.		N/A
	Appropriate interlocking is provided, when non-operation of an auxiliary function (for example lubrication, supply of coolant, swarf removal) can cause a hazardous situation, or cause damage to the machine or to the work in progress.		N/A
9.3.4	Interlocks between different operations and for contrary motions are provided if this operations lead to hazardous situations.		P
9.3.5	Reverse current braking: Where braking of a motor is accomplished by current reversal, measures prevent the motor starting in the opposite direction at the end of braking where that reversal can cause a hazardous situation or damage to the machine or to the work in progress.		N/A
9.4	Control functions in the event of failure		P
9.4.1	The safety related electrical control circuits have an appropriate level of safety performance that has been determined from the risk assessment at the machine. The requirements of IEC 62061 and/or ISO 13849-1, ISO 13849-2 are met.		P
	Where memory retention is achieved for example, by battery power, measures are taken to prevent hazardous situations arising from failure or removal of the battery.		P
	Means are provided to prevent unauthorized or inadvertent memory alteration by, e.g. requiring the use of a key, access code or tool.		P
9.4.2	Measures are taken to minimize risk in the event of failure:		—
9.4.2.1	- Use of proven circuit techniques and components		P
9.4.2.2	- Provisions of partial or complete redundancy		N/A
9.4.2.3	- Provision of diversity		N/A
9.4.2.4	- Provision for functional tests		P
9.4.3	Protection against mal-operation due to earth faults, voltage interruptions and loss of circuit continuity		—
9.4.3.1	Earth faults on any control circuit don't cause unintentional starting, potentially hazardous motions, or prevent stopping of the machine. Methods to meet these requirements include but are not limited to the following:		—
	a) 1) Control circuits, fed by control transformers and connected to the protective bonding circuit at the point of supply. (PELV) (see Figure 3 of this standard)		P
	a) 2) Control circuits, fed by control transformers without connection to the protective bonding circuit at the point of supply in the arrangement according to figure 3 and having a device that interrupts the circuit automatically in the event of an earth fault		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	b) Control circuits fed by a control transformer with a centre-tapped winding, this centre tap connected to the protective bonding circuit, arranged as shown in Figure 4 of this standard with the overcurrent protective device having switching elements in all control circuit supply conductors.		N/A
	c) Where the control circuit is not fed from a control transformer and is either: 1) directly connected between the phase conductors of an earthed supply, or; 2) directly connected between the phase conductors or between a phase conductor and a neutral conductor of a supply that is not earthed or is earthed through a high impedance, multipole switch that switch all live conductors are used for those functions that can cause hazardous situations or damage to the machine.		N/A
	Or in case of c) 2), a device is provided that interrupts the circuit automatically in the event of an earth fault.		N/A
9.4.3.2	For control systems using a memory device(s), proper functioning in the event of power failure is ensured (e.g. by using a non-volatile memory) to prevent any loss of memory that can result in a hazardous situation.		N/A
9.4.3.3	Upon sliding contacts the loss of continuity of safety-related control circuits depending on, can result in a hazardous situation. Appropriate measures are taken (for example by duplication of the sliding contacts).		N/A

10	OPERATOR INTERFACE AND MACHINE-MOUNTED CONTROL DEVICES		P
10.1.1	As far as is practicable, those devices are selected, mounted, and identified or coded in accordance with relevant parts of IEC 61310.		P
10.1.2	As far as is practicable, machine-mounted control devices are: – readily accessible for service and maintenance;		P
	– mounted in such a manner as to minimize the possibility of damage from activities such as material handling.		P
	The actuators of hand-operated control devices are selected and installed so that: – they are not less than 0,6 m above the servicing level and		P
	– are within easy reach of the normal working position of the operator;		P
	– the operator is not placed in a hazardous situation when operating them.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The actuators of foot-operated control devices are selected and installed so that: – they are within easy reach of the normal working position of the operator;		N/A
	– the operator is not placed in a hazardous situation when operating them.		P
10.1.3	The degree of protection (see IEC 60529) together with other appropriate measures does afford protection against:		P
	– the effects of aggressive liquids, vapours, or gases found in the physical environment or used on the machine;		P
	– the ingress of contaminants (for example swarf, dust, particulate matter).		P
	The operator interface control devices has a minimum degree of protection against direct contact of IPXXD (see IEC 60529).		P
10.1.4	Position sensors (for example position switches, proximity switches) are so arranged that they will not be damaged in the event of overtravel.		P
	Position sensors in circuits with safety-related control functions shall have direct opening action (see IEC 60947-5-1) or shall provide similar reliability (see 9.4.2).		P
10.1.5	Portable and pendant operator control stations and their control devices are so selected and arranged as to minimize the possibility of inadvertent machine operations caused by shocks and vibrations		N/A
10.2	Push-buttons		P
10.2.1	Mandatory: The colour RED is used only for emergency stop and emergency switching off actuators.		P
	The recommend colours of push-buttons are as shown in table 2 of this standard.		P
10.2.2	The recommend markings on push-buttons are as shown in table 3 of this standard.		P
10.3	Indicator lights and displays		P
10.3.1	Indicator lights and displays are selected and installed in such a manner as to be visible from the normal position of the operator (see also IEC 61310-1).		P
	Indicator light circuits used for warning lights are fitted with facilities to check the operability of these lights.		N/A
	The recommend colours on Indicator light are as shown in table 4 of this standard.		N/A
	Indicating towers on machines have the applicable colours in the following order from the top down; RED, YELLOW, BLUE, GREEN and WHITE.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Where flashing lights or displays are used to provide higher priority information, audible warning devices should also be provided.		N/A
10.4	illuminated push-button actuators are colour-coded in accordance with Tables 2 and 4. Where there is difficulty in assigning an appropriate colour, WHITE is used.		P
	The colour RED for the emergency stop actuator shall not depend on the illumination of its light.		N/A
10.5	Devices having a rotational member, such as potentiometers and selector switches, have means of prevention of rotation of the stationary member. Friction alone isn't considered sufficient.		N/A
10.6	Actuators used to initiate a start function or the movement of machine elements (for example slides, spindles, carriers) are constructed and mounted so as to minimize inadvertent operation.		N/A
10.7	Emergency stop devices		P
10.7.1	Devices for emergency stop are readily accessible.		P
	They are located at each operator control station and at other locations where the initiation of an emergency stop can be required (exception: see 9.2.7.3).		P
10.7.2	Allowed types of device for emergency stop: – a push-button operated switch with a palm or mushroom head type; – a pull-cord operated switch; – a pedal-operated switch without mechanical guard.	– a push-button operated switch with mushroom head type;	P
	The devices are direct opening operation (see IEC 60947-5-1, Annex K).		P
10.7.3	Actuators are coloured RED. If a background exists immediately around the actuator, then this background is coloured YELLOW. See also ISO 13850.		P
10.7.4	The supply disconnecting device may be locally operated to serve the function of emergency stop when: – it is readily accessible to the operator; and – it is of the type described in 5.3.2 a), b), c), or d). When also intended for this use, the supply disconnecting device meets the colours RED/YELLOW.		P
10.8	Emergency switching off device		N/A
10.8.1	Means are provided, where necessary, to avoid confusion between these devices.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
10.8.2	The types of device for emergency switching off include: – a push-button operated switch with a palm or mushroom head type of actuator; – a pull-cord operated switch. The devices are direct opening action (see IEC 60947-5-1, Annex K). The push-button operated switch may be in a break-glass enclosure.		N/A
10.8.3	Actuators are coloured RED. If a background exists immediately around the actuator, then this background is coloured YELLOW. See also ISO 13850.		N/A
10.8.4	Where the supply disconnecting device is to be locally operated for emergency switching off, it is be readily accessible and meets the colours RED/YELLOW.		N/A
10.9	Enabling control device		P
	An enabling control device as a part of a system, does allow operation when actuated in one position only. In any other position, operation is stopped or prevented.		P
	Functions of two-position types: position 1: off-function of the switch (actuator is not operated); position 2: enabling function (actuator is operated)		N/A
	Functions of three-position types: position 1: off-function of the switch (actuator is not operated); position 2: enabling function (actuator is operated in its mid position); position 3: off-function (actuator is operated past its mid position); when returning from position 3 to position 2, the enabling function is not activated.		N/A

11	CONTROLGEAR: LOCATION, MOUNTING AND ENCLOSURES		P
11.2.1	All items of controlgear (inclusively terminals that are not part of controlgear components or devices) are placed and oriented so that they can be identified without moving them or the wiring.		P
	For items that require checking for correct operation or that are liable to need replacement, those actions should be possible without dismantling other equipment or parts of the machine (except opening doors or removing covers, barriers or obstacles).		N/A
	All controlgear are mounted so as to facilitate its operation and maintenance from the front.		P
	Where access is required for regular maintenance or adjustment, the relevant devices shall be located between 0,4 m and 2,0 m above the servicing level.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Only operating, indicating, measuring, and cooling devices are mounted on doors or on normally removable access covers of enclosures.		N/A
	Plug-in arrangements of control devices and plug-in-devices:		—
	The connection is clearly identified by shape, marking or reference designation, singly or in combination.		N/A
	When they have to be handled during normal operation means are provided with non-interchangeable features where the lack of such a facility can result in malfunctioning.		N/A
	Plug/socket combinations that are handled during normal operation are unobstructedly accessible.		N/A
	Test points for connection of test equipment are: – unobstructedly accessible; – clearly identified to correspond with the documentation; – adequately insulated; – sufficiently spaced.		N/A
11.2.2	Non-electrical parts and devices, not directly associated with the electrical equipment, are not located within enclosures containing controlgear.		P
	Devices such as solenoid valves are separated from the other electrical equipment (for example in a separate compartment).		P
	Control devices mounted in the same location and connected to the supply voltage, or to both supply and control voltages, are grouped separately from those connected only to the control voltages.		P
	Terminals shall be separated into groups for: – power circuits; – associated control circuits; – other control circuits, fed from external sources (for example for interlocking).		P
11.2.3	Heat generating components (for example heat sinks, power resistors) are located so, that the temperature of each component in the vicinity remains within the permitted limit.		N/A
	Controlgears are sufficiently protected against: - ingress of solid foreign objects - liquids - dust, coolants, and swarf, taking into account the external influences under which the machine is intended to operate (i.e. the location and the physical environmental conditions).		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Enclosures of control gear provide a degree of protection of at least IP22 (see IEC 60529). <u>Exceptions:</u> a) specific electrical operating area b) When with removable collectors on conductor wire or conductor bar systems do not achieve IP22 measures of 6.2.5 are applied.	see test report 2ae-20-248/28.02.2020 cl. 2	P
11.4	Enclosures, doors and openings		P
	Enclosures (inclusively screens of windows (windows: toughened glass or polycarbonate sheet of not less than 3 mm thickness), joints, gaskets of doors and lids) do withstand the foreseeable mechanical, electrical and thermal stresses and other environmental factors and of the aggressive liquids, vapours, or gases used on the machine.		P
	Enclosure doors are not wider than 0,9 m and have vertical hinges, with an angle of opening > 95°.		P
	Openings in enclosures (for example, for cable access), including those towards the floor or foundation or to other parts of the machine are equipped with means to ensure the degree of protection specified for the equipment. A suitable opening may be provided in the base of enclosures within the machine so that moisture due to condensation can drain away.		P
	Openings for cable entries shall be easily re-opened on site.		P
	No openings between enclosures containing electrical equipment and compartments containing coolant, lubricating or hydraulic fluids, or those into which oil, other liquids, or dust can penetrate.		N/A
	Holes in an enclosure for mounting do not impair the required protection.		P
	Equipment that, in normal or abnormal operation, can attain a surface temperature sufficient to cause a risk of fire or harmful effect to an enclosure material is: – located within an enclosure that will withstand, such temperatures; and – is located at a sufficient distance from adjacent equipment allowing safe dissipation of heat (see also 11.2.3); or – is otherwise screened by material that can withstand to the harmful effect.		N/A
11.5	Access to control gear		N/A
	Doors in gangways for access to electrical operating areas: – are at least 0,7 m wide and 2,1 m high; – do open outwards; – have a means (for example panic bolts) to allow opening from the inside without the use of a key or tool.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Enclosures which readily allow a person to fully enter are be provided with means to allow escape, e.g. panic bolts on the inside of doors.		N/A
	Enclosures intended for such access, for example for resetting, adjusting, maintenance, shall have a clear width of at least 0,7 m and a clear height of at least 2,1 m When equipment is likely to be live during access with > 1,0m and when on both side with > 1.5m.		N/A

12	CONDUCTORS AND CABLES		P
	IMPORTANT: The following requirements do not apply to the integral wiring of assemblies, subassemblies, and devices that are manufactured and tested in accordance with their relevant IEC standard (for example IEC 60439-1).		—
12.2	In general, conductors are of copper. Where aluminium conductors are used, the cross-sectional area is at least 16 mm ² .		P
	The cross-sectional areas of conductors are according to Table 5 and its notes.		P
	All conductors that are often in movement (> one movement per hour of machine operation) have flexible stranding of class 5 or class 6.		P
	Where the insulation of conductors and cables (for example PVC) can constitute hazards due to the propagation of a fire or the emission of toxic or corrosive fumes adequate means are provided. Special attention is given to the integrity of a circuit having a safety-related function		N/A
	Minimum insulation test voltages for used cables are: – ≥ 2 000 V a.c. for a duration of 5 min for operation at voltages higher than 50 V a.c. or 120 V d.c., or – ≥ 500 V a.c. for a duration of 5 min for PELV circuits (see IEC 60364-4-41, class III equipment).		P
	Insulation strong enough to withstand damage due to operation or during laying, especially for cables pulled into ducts.		P
12.4	Current-carrying capacity in normal service in accordance with table 6. Or in accordance with suppliers recommendation.		P
12.6	Flexible cables		P
12.6.1	All flexible cables have Class 5 or Class 6 conductors.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Cables under severe duties are adequately protected against: - abrasion due to mechanical handling and dragging across rough surfaces; - kinking due to operation without guides; - stress resulting from guide rollers and forced guiding, being wound and re-wound on cable drums.		P
12.6.2	The tensile stress applied to copper conductors does not exceed 15 N/mm ² of cross-sectional area. Or special measures are taken to withstand the applied stress. For material other than copper the applied stress is within the cable manufacturer's specification.		N/A
12.6.3	For cables installed on drums, the maximum current-carrying capacity in free air is derated in accordance with Table 7.		N/A
12.7	Conductor wires, conductor bars and slip-ring assemblies		N/A
12.7.1	During normal access to the machine, protection against direct contact to conductor wires, conductor bars and slip-ring assemblies is achieved by the application of one of the following protective measures: - protection by partial insulation of live parts, or where this is not practicable; - protection by enclosures or barriers of at least IP2X.		N/A
	Horizontal top surfaces of barriers or enclosures that are readily accessible provide a degree of protection of at least IP4X.		N/A
	Where the required degree of protection is not achieved, protection by placing live parts out of reach in combination with emergency switching off in accordance with 9.2.5.4.3 is applied.		N/A
	Conductor wires and conductor bars are so placed / protected as to: - prevent contact with conductive items such as the cords of pull-cord switches, strain-relief devices and drive chains; - prevent damage from a swinging load.		N/A
12.7.2	Protective conductor circuit (PE) and the neutral conductor (N) each use a separate conductor wire, conductor bar or slip-ring.		N/A
	The continuity of the protective conductor circuit using sliding contacts is ensured by taking appropriate measures (for example, duplication of the current collector, continuity monitoring)		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
12.7.3	Protective conductor current collectors have a shape or construction so that they are not interchangeable with the other current collectors. Such current collectors shall be of the sliding contact type.		N/A
12.7.4	Removable current collectors (e.g. swivelingable) with disconnecter function: The protective conductor circuit interrupts after and reconnects before any live conductor.		N/A
12.7.5	Clearances in air between conductors and adjacent systems are suitable at least a rated impulse voltage of an overvoltage category III in accordance with IEC 60664-1 (For example 4 kV for 230/400 V systems → clearances 3mm)		N/A
12.7.6	Creepage distances between conductors and adjacent systems are suitable suitable for operation in the intended environment, e.g. open air (IEC 60664-1), inside buildings, protected by enclosures. In abnormally dusty, moist or corrosive environments, the following creepage distance requirements apply: – unprotected conductor etc.: minimum creepage dist. of 60 mm – enclosed conductor etc.: minimum creepage distance of 30 mm		N/A
12.7.7	Conductor system divided into isolated sections: suitable design measures are employed to prevent the energization of adjacent sections by the current collectors themselves.		N/A
12.7.8	Construction of conductor wires etc.: - power circuits are grouped separately from those in control circuits. - do withstand the foreseeable mechanical forces and thermal effects of short-circuit current. - covers can not be opened without the use of a tool - all conductive parts of accompanying enclosures are connected to the protective bonding circuit - underground and underfloor conductor bar ducts have drainage facilities		N/A

13	WIRING PRACTICES		P
13.1	Connections and routing		P
13.1.1	All connections are secured against accidental loosening.		P
	The means of connection are suitable for the cross-sectional areas and nature of the conductors being terminated.		P
	No connection of two or more conductors to one terminal, unless the terminal is designed for it.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	No soldered connections to terminals unless they are suitable for it.		N/A
	Terminals on terminal blocks are plainly marked or labelled corresponding with the diagrams.		P
	Installations of flexible conduits and cables are such that liquids drain away from the fittings.		P
	Retaining means for conductor strand and shields provided (no soldering for that purpose)		N/A
	Identification tags legible, permanent, and appropriate for the physical environment.		P
	Terminal blocks mounted and wired so that the internal and external wiring does not cross over the terminals (see IEC 60947-7-1).		P
13.1.2	Conductors and cables run from terminal to terminal without splices or joints. Connections using plug/socket combinations with suitable protection against accidental disconnection are not considered to be joints for the purpose of this subclause.		P
	Terminations of cables are adequately supported to prevent mechanical stresses at the terminations of the conductors.		P
	Protective conductor placed close to the associated live conductors in order to decrease the impedance of the loop.		P
13.1.3	Conductors for circuits that operate at different voltages are separated by suitable barriers, or are insulated for the highest voltage that occurs within the same duct.		N/A
13.1	Connections and routing		P
13.2.1	Each conductor is identifiable at each termination in accordance with the technical documentation.		P
13.2.2	The protective conductor has the bicolour combination GREEN-AND-YELLOW Where the protective conductor can be easily identified colour coding throughout its length is not necessary, but the ends or accessible locations are clearly identified by the graphical symbol or by the bicolour combination GREEN-AND-YELLOW.		P
13.2.3	Neutral conductors are identified by the colour LIGHT BLUE. That colour is not used for identifying any other conductor where confusion is possible.		P
	Bare conductors used as neutral conductors have at minimum a stripe in LIGHT BLUE 15 mm to 100 mm wide in each compartment or unit and at each accessible location.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Identification by colour for other conductors: Colours GREEN or YELLOW are not used. (Details to colour coding see this norm Cl. 13.2.3)		P
13.3	Wiring inside enclosures		P
	Conductors inside enclosures are supported where necessary. Conductors and cables that do not run in ducts are adequately supported.		P
	Non-metallic supports are made with a flame-retardant insulating material (see IEC 60332 series)		P
	Connections to devices mounted on doors or to other movable parts are using flexible conductors in accordance with 12.2 and 12.6.		P
13.4	Wiring outside enclosures		P
13.4.2	Conductors and their connections external to the electrical equipment are placed in suitable ducts (see cl.13.5). Exceptions: - Cables with special suitable protection. - Position switches or proximity switches supplied with a dedicated cable which is sufficiently short.		N/A P N/A
	Connections to moving elements of the machine are made of flexible cable in accordance with 12.2 and 12.6.		P
	Bending radius of the cable are of at least 10 times the diameter of the cable		P
	Cables close to moving parts, maintain a space of at least 25 mm between the moving parts and the cables or barriers are provided.		P
	Cable handling systems: Lateral cable angles do not exceeding 5°, at being wound on and off cable drums or approaching and leaving cable guidance devices. The bending radius is in accordance with table 8.		N/A
13.4.4	Interconnection of devices on the machine is made through adequate terminals.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
13.4.5	Requirements to plug/socket combinations outside of enclosures: Exceptions: components connected to a bus system by a plug/socket combination a) Prevention for unintentional contact with live parts at any time. At least IPXXB. (PELV circuits are excepted from this requirement.) b) First make last break protective bonding contact if used in TN- or TT-systems. c) Sufficient load-breaking capacity, when intended to be disconnected under running conditions. When rated at ≥ 30 A interlocked with a switching device d) When rated at ≥ 16 A having a retaining means to prevent unintended or accidental disconnection. e) when unintended or accidental disconnection +can cause a hazardous situation, having a retaining means. f) Component remaining live after disconnection having at least IP2X or IPXXB, taking into account the required clearance and creepage distances.(PELV circuits are excepted from this requirement.) g) Metallic housings of plug/socket combinations being connected to the protective bonding circuit. (PELV circuits are excepted from this requirement.) h) Having retaining means to prevent unintended or accidental disconnection and being marked that they are not intended to be disconnected under load. i) Clearly identifiable if more then one plug / socket per device. It is recommended that mechanical coding being used. j) When used in control circuits fulfilling the applicable requirements of IEC 61984. Exception: see item k). k) No plug/socket combinations intended for household and similar general purposes used for control circuits. In plug/socket combinations in accordance with IEC 60309-1, only those contacts shall be used for control circuits which are intended for those purposes. Exception: The requirements of item k) do not apply to control functions using high frequency signals on the power supply.		P
13.4.6	Protection of Plug / socket from the physical environment during transportation and storage.		P
13.5	Ducts, connection boxes and other boxes		P
	Provided with a degree of protection suitable for the application.		N/A
	No sharp edges, flash, burrs, rough surfaces, or threads with which the insulation of the conductors can come into contact.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Where human passage is required, least 2 m above the working surface.		N/A
	Not used as connection for protective bonding circuit.		N/A
	Where cable trays are a.s.o. are only partially covered, the cables used are of a suitable type.		N/A
13.5.2	Filling the percentage of ducts adapted to the straightness and length of the duct and the flexibility of the conductors.		N/A
13.5.3	Rigid metal conduit and fittings shall galvanized steel or of a corrosion-resistant material		N/A
	Fittings compatible with the conduit.		N/A
	Conduit bends properly made		N/A
13.5.4	Flexible metal tubing or woven wire armour suitable for the expected physical environment.		N/A
13.5.5	Flexible non-metallic conduit resistant to kinking and suitable for the expected physical environment.		N/A
13.5.6	Requirements to cable trunking systems: - Rigidly supported and clear of all moving or contaminating portions of the machine - Covers overlapping the sides and attached.		N/A
13.5.7	The compartments of machine used as cable trunking systems are isolated from coolant or oil reservoirs and are entirely enclosed, and the conductors are secured.		N/A
13.5.8	Connection boxes and other boxes used for wiring: - Are accessible for maintenance. - Provide protection against the ingress of solid bodies and liquids, taking into account the external influences under which the machine is intended to operate (see 11.3). - Do not have unused knockouts etc.		P
13.5.9	Motor connection boxes: Encloses only connections to the motor and motor-mounted devices (e.g brakes, temperature sensors)		P

14	ELECTRIC MOTORS AND ASSOCIATED EQUIPMENT		P
14.1	Electric motors are conform to the relevant parts of IEC 60034 series.		P
	There protection is conform to the requirements given in 7.2 for overcurrent protection, in 7.3 for overload protection, and in 7.6 for overspeed protection.		N/A
14.2	Minimal IP23 protection for all motors. More stringent requirements depending on the application and the physical environment.		P
14.4	Motors incorporated as an integral part of the machine are adequately protected from mechanical damage.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	motors and its associated parts (inclusively motor connection box) are easily accessible for inspection and maintenance etc		P
	Cooling is ensured and the temperature rise remains within the limits of the insulation class (see IEC 60034-1)		N/A
14.5	The characteristics of motors and associated equipment are selected in accordance with the anticipated service and physical environmental conditions (see 4.4). Detailed criteria see 14.5 of this norm.		P
14.6	Overload and overcurrent protective devices for mechanical brake actuators initiate simultaneously the deenergization (release) of the associated motors.		N/A
15	ACCESSORIES AND LIGHTING		N/A
15.1	Requirements for socket-outlets for accessory equipment: – conform to IEC 60309-1 (Where that is not practicable, they are clearly marked with voltage and current ratings); – continuity of the protective bonding circuit to the socket-outlet is ensured, except where protected by PELV; – unearthed conductors connected to the socket-outlet are overcurrent- and if required overload-protected – protection is separately from other circuits; – power supply to the socket-outlet is not disconnected by the supply disconnecting device for the machine or the section of the machine, the requirements of 5.3.5 apply.		N/A N/A N/A N/A N/A
15.2.1	Requirements for local lighting of the machine and equipment: - protective bonding circuit in accordance with 8.2.2. - ON/OFF switch incorporated in the lamp-holder or in the flexible connecting cords. - Stroboscopic effects avoided. - Where fixed lighting electromagnetic compatibility is taken into account.		N/A



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
15.2.2	Requirements to the power supply for local lighting: – Nominal voltage not exceeding 250 V between conductors – isolating transformer connected to the load side of the supply with overcurrent protection in the secondary circuit; or – isolating transformer connected to the line side of the supply disconnecting device with overcurrent protection in the secondary circuit. That source is permitted for maintenance lighting circuits in control enclosures only; or – from a machine circuit with dedicated overcurrent protection; or – from an isolating transformer connected to the line side of the supply disconnecting device, provided with a dedicated primary disconnecting means and secondary overcurrent protection, and mounted within the control enclosure adjacent to the supply disconnecting device; or – from an externally supplied lighting circuit (for example factory lighting supply). This shall be permitted in control enclosures only, and for the machine work light(s) where their total power rating is not more than 3 kW. Exception: Where fixed lighting is out of reach of operators during normal operations, the provisions of this subclause do not apply.		N/A
15.2.3	All unearthed conductors of circuits supplying lighting have their own overcurrent protecting devices.		N/A
15.2.4	Requirements to the fittings for local lighting: – Adjustable lighting fittings are suitable for the physical environment. – lamp holders are in accordance with the relevant IEC standard; – lamp holders are constructed with an insulating material protecting the lamp cap – Reflectors are supported by a bracket and not by the lamp holder. Exception: where fixed lighting is out of reach of operators during normal operation, the provisions of this subclause do not apply.		N/A
16	MARKING, WARNING SIGNS AND REFERENCE DESIGNATIONS		P
16.1	Warning signs, nameplates, markings, and identification plates are of sufficient durability to withstand the physical environment.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
16.2.1	Enclosures that do not clearly show that they contain electrical equipment that has a risk of electric shock are marked with the graphical symbol  plainly visible on the enclosure door or cover. Exception: – enclosure equipped with a supply disconnecting device; – operator-machine interface or control station; – a single device with its own enclosure (for example position sensor).		P
16.2.2	Hazardous hot surfaces of the electrical equipment, are equipped with the graphical warning symbol 		P
16.2.3	Control devices, visual indicators, and displays are clearly and durably marked to their functions.		P
16.2.4	Equipment (e.g. controlgear assemblies) is legibly and durably marked. A nameplate is attached to the enclosure adjacent to each incoming supply with: – name or trade mark of supplier; – certification mark, when required; – serial number, where applicable; – rated voltage, number of phases and frequency (if a.c.), – full-load current for each supply; – short-circuit rating of the equipment; – main document number (see IEC 62023).		P P P P P - -
16.2.5	All enclosures, assemblies, control devices, and components are plainly identified with the same reference designation as shown in the technical documentation.		P
17	TECHNICAL DOCUMENTATION		P
17.1	Documentation in agreed language provided.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
17.2	Information provided with the electrical equipment include: a) A main document (parts list or list of documents); b) Complementary documents including: 1) a clear, comprehensive description of the equipment, installation and mounting, and the connection to the electrical supply(ies); 2) electrical supply(ies) requirements; 3) information on the physical environment (for example lighting, vibration, noise levels, atmospheric contaminants) where appropriate; 4) overview (block) diagram(s) where appropriate; 5) circuit diagram(s); 6) information (as applicable) on: -programming, as necessary for use of the equipment; - sequence of operation(s); -frequency of inspection; -frequency and method of functional testing; -guidance on the adjustment, maintenance, and repair, particularly of the protective devices and circuits; -recommended spare parts list; -list of tools supplied. 7) a description (including interconnection diagrams) of the safeguards, interlocking functions, and interlocking of guards against hazards, particularly for machines operating in a co-ordinated manner; 8) a description of the safeguarding and of the means provided where it is necessary to suspend the safeguarding (for example for setting or maintenance), (see 9.2.4); 9) instructions on the procedures for securing the machine for safe maintenance; (see also 17.8); 10) information on handling, transportation and storage; 11) information regarding load currents, peak starting currents and permitted voltage drops, as applicable; 12) information on the residual risks due to the protection measures adopted, indication of whether any particular training is required and specification of any necessary personal protective equipment.		P
			P
			P
			P
			P
			P
			P
			P
			P
			P
			P
			P
			P
17.3	Unless otherwise agreed between manufacturer and user: – the documentation is in accordance with relevant parts of IEC 61082; – reference designations are in accordance with relevant parts of IEC 61346; – instructions / manuals are in accordance with IEC 62079. – parts lists where provided are in accordance with IEC 62027, class B.		P
			P
			P
			P
			P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
17.4	Installation documents giving all information necessary for the preliminary work of setting up the machine (including commissioning) are provided. (In complex cases, it may be necessary to refer to the assembly drawings for details.)		P
	The recommended position, type, and cross-sectional areas of the supply cables to be installed on are clearly indicated.		N/A
	Data necessary for choosing the type, characteristics, rated currents, and setting of the overcurrent protective device for the supply conductors to the electrical equipment of the machine is stated (see 7.2.2).		N/A
	The size, purpose, and location of any ducts in the foundation that are to be provided by the user are detailed (see Annex B).		N/A
	The size, type, and purpose of ducts, cable trays, or cable supports between the machine and the associated equipment that are to be provided by the user are detailed (see Annex B).		N/A
	A diagram indicates where space is required for the removal or servicing of the electrical equipment.		N/A
	An interconnection diagram or table is provided, where it is appropriate. They give full information about all external connections.		P
	Where the electrical equipment is intended to be operated from more than one source of electrical supply, the interconnection diagram or table does indicate the modifications or interconnections required for the use of each supply.		N/A
17.5	Where it is necessary to facilitate the understanding of the principles of operation, an overview diagram is provided.		N/A
17.6	The circuit diagram shows the electrical circuits on the machine and its associated electrical equipment.		N/A
	Any graphical symbol not shown in IEC 60617-DB:2001 are separately described on the diagrams or supporting documents.		N/A
	The symbols and identification of components and devices are consistent throughout all documents and on the machine.		N/A
	Switch symbols on the electromechanical diagrams are shown with all supplies turned off (for example electricity, air, water, lubricant) and with the machine and its electrical equipment ready for a normal start.		N/A
	Conductors are identified in accordance with 13.2.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	Characteristics relating to the function of the control devices and components which are not evident from their symbolic representation are included on the diagrams adjacent to the symbol or referenced to a footnote.		N/A
17.7	An operating manual detailing proper procedures for set-up and use of the electrical equipment is provided.		P
	Particular attention is given to the safety measures.		P
	Where the operation of the equipment can be programmed, detailed information on methods of programming, equipment required, program verification, and additional safety procedures (where required) is given.		N/A
17.8	A maintenance manual detailing proper procedures for adjustment, servicing and preventive inspection, and repair is provided. Recommendations on maintenance/service intervals and records are part of that manual. Where methods for the verification of proper operation are provided (for example software testing programs), the use of those methods is detailed		P
17.9	The parts list, where provided, comprises, as a minimum, information necessary for ordering spare or replacement parts (for example components, devices, software, test equipment, technical documentation) required for preventive or corrective maintenance including those that are recommended to be carried in stock by the user of the equipment.		P

18	VERIFICATION	P
18.1	The extent of verification will be given in the dedicated product standard for a particular machine. Where there is no dedicated product standard for the machine, the verifications shall always include the items a), b) and f) and may include one or more of the items c) to e): a) verification that the electrical equipment complies with its technical documentation; b) in case of protection against indirect contact by automatic disconnection, conditions for protection by automatic disconnection shall be verified according to 18.2; c) insulation resistance test (see 18.3); d) voltage test (see 18.4); e) protection against residual voltage (see 18.5); f) functional tests (see 18.6).	—
18.2	Verification of conditions for protection by automatic disconnection of supply	P
18.2.2	Test 1: Verification of the continuity of the protective bonding circuit	



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict
	The resistance of each protective bonding circuit between the PE terminal and relevant points that are part of each protective bonding circuit is measured with a current between at least 0,2 A. And the resistance measured is in the expected range according to the length, the cross sectional area and the material of the related protective bonding conductor. table A.3 $R_{PE} \leq 50/I_a$ or $R_{PE} \leq 2,0 \Omega$	see test report 2ae-20-248/28.02.2020 cl. 4.1	P
	Test 2: Fault loop impedance verification and suitability of the associated overcurrent protective device.		N/A
	The connections of the power supply and of the incoming external protective conductor to the PE terminal of the machine are verified by inspection.		N/A
	The conditions for the protection by automatic disconnection of supply in accordance with 6.3.3 and Annex A are verified by both: 1) A verification of the fault loop impedance by - calculation, or - measurement in accordance with A.4, and		N/A
	2) A confirmation that the setting and characteristics of the associated overcurrent protective device are in accordance with the requirements of Annex A or table 10		N/A
18.3	Insulation resistance tests (facultative) The insulation resistance measured at 500 V d.c. between the power circuit conductors and the protective bonding circuit are not less than 1 MΩ.	see test report 2ae-20-248/28.02.2020 cl. 5	P
18.4	Voltage test (facultative) Testing voltage; twice the rated supply voltage of the equipment or 1 000 V whichever is the greater With test voltage applied between the power circuit conductors and the protective bonding circuit for a period of approximately 1 s. there is no disruptive discharge occurred.	see test report 2ae-20-248/28.02.2020 cl. 6	P
18.5	Protection against residual voltages (facultative) Compliance with 6.2.4. is ensured	see test report 2ae-20-248/28.02.2020 cl. 7	P
18.6	Functional tests The function of circuits for electrical safety (for example earth fault detection) is insured.		P



IEC 60204-1			
Clause	Requirement - Test	Result - Remark	Verdict

PHOTO DOCUMENT

